



- NOTES:**
- RESIDENTIAL - 14' MIN TO 24' MAX WIDTH, 6" THICK CONCRETE WITHIN RIGHT OF WAY.
  - NO REINFORCING REQUIRED IN DRIVE APPROACH OR SIDEWALK.
  - EXISTING CONCRETE CURB MAY NOT BE SAW CUT TO PROVIDE A DEPRESSED AREA. THE CURB MUST BE REMOVED AND REPLACED.
  - NO REBAR BETWEEN THE EXISTING CURB AND NEW APPROACH ALLOWED.
  - CASTINGS PLACED WITHIN HARD SURFACES NEED TO BE FLUSH WITH SURFACE. NO EXPANSION MATERIAL AROUND CASTING.
  - NO #2 AGG. FROM THE TEMPORARY CONSTRUCTION ENTRANCE MAY BE VISIBLE WITHIN THE SUBBASE. PLACE 4" OF COMPACTED SAND, #53 PROCESS GRAVEL OR #53 CRUSHED CONCRETE OVER THE #2 AGGREGATE.

<p><b>The City Of Goshen</b></p> <p>Department of Public Works &amp; Safety</p> <p>Office of Engineering</p> <p>204 East Jefferson Street, Goshen, Indiana 46528</p> <p>Phone: 574-534-2201 Fax: 574-533-8626</p>		Project Number:	PROJECT-NUMBER
		Designed By:	Approved By:
Drafted By:	Date:		
JRH	03/14/2022		
Scale:		NTS	
		<b>"X"-NUMBER</b>	