



- NOTES:**
- RESIDENTIAL - 12' MIN TO 24' MAX WIDTH, 6" THICK CONCRETE WITHIN RIGHT OF WAY.
 - NO REINFORCING REQUIRED IN DRIVE APPROACH OR SIDEWALK.
 - EXISTING CONCRETE CURB MAY NOT BE SAW CUT TO PROVIDE A DEPRESSED AREA. THE CURB MUST BE REMOVED AND REPLACED.
 - NO REBAR BETWEEN THE EXISTING CURB AND NEW APPROACH ALLOWED.
 - CASTINGS PLACED WITHIN HARD SURFACES NEED TO BE FLUSH WITH SURFACE. NO EXPANSION MATERIAL AROUND CASTING.
 - NO #2 AGG. FROM THE TEMPORARY CONSTRUCTION ENTRANCE MAY BE VISIBLE WITHIN THE SUBBASE. PLACE 4" OF COMPACTED SAND, #53 PROCESS GRAVEL OR #53 CRUSHED CONCRETE OVER THE #2 AGGREGATE.

The City Of Goshen Department of Public Works & Safety Office of Engineering 204 East Jefferson Street, Goshen, Indiana 46528 Phone: 574-534-2201 Fax: 574-533-8626		Project Number:	PROJECT-NUMBER
		Designed By:	Approved By:
JRH	DKS	Drafted By:	Date:
JRH	07/24/2024	Scale:	NTS
		"X"-NUMBER	