

**OBSTACLES WITHIN SIDEWALK:**

- POLES - 1/2" FOAM EXPANSION MATERIAL AROUND POLE, SAW CUT CONTRACTION JOINT
- SIGN POST - 4" PVC SLEEVE, NO EXPANSION MATERIAL AROUND SLEEVE
- CITY REPRESENTATIVE TO BE CONSULTED FOR REQUIRED TREATMENT FOR OTHER OBSTACLES
- SIDEWALK ALIGNMENT CHANGES TO AVOID OBSTACLES MUST BE PRE-APPROVED

1/2" FIBER BOARD OR FOAM EXPANSION MATERIAL, FULL DEPTH AND WIDTH. INSTALL AT DRIVE APPROACH EDGES, JOINT BETWEEN EXISTING AND NEW SIDEWALK AND EVERY 40' ALONG SIDEWALK

6' X 6' SECTIONS, SAW CUT CONTRACTION JOINT AT EACH SECTION, 1/3 THE DEPTH OF MATERIAL. SAW CUT WITHIN 24 HOURS OF PLACEMENT  
**NO TOOLED JOINTS**

2.0' MIN. FROM SIDEWALK  
(FIRE HYDRANT)

SAW CUT CONTRACTION JOINT AT CASTINGS WITHIN SIDEWALK

USE A PLUG CURB BOX LID WITH 1" PENTAGON PLUG WHEN THE CURB BOX IS LOCATED WITHIN A HARD SURFACE AREA. INSTALL SLIGHTLY LOWER THAN FINISHED SURFACE TO PREVENT A TRIP HAZARD. IF HIGH OR LOW AND WOULD CAUSE A TRIP HAZARD, THE PANEL WILL NEED REPLACED AND CURB BOX ADJUSTED. IF UNABLE TO ADJUST AN EXISTING CURB STOP, CONTACT THE CITY SEWER AND WATER DEPARTMENT FOR ASSISTANCE  
**NO EXPANSION MATERIAL OR PVC PIPE AROUND LID**

USE NEENAH #3-4055 OR EQUAL CASTING OVER PVC CLEANOUT WITHIN A HARD SURFACE AREA. WORD 'SEWER' STAMPED ON LID.  
**NO EXPANSION MATERIAL OR PVC PIPE AROUND CASTING**

**NOTES:**

1. 4" CLASS 'A' CONCRETE, 4,000 PSI OVER 4" COMPACTED No 53 CRUSHED/RECYCLED CONCRETE
2. RESTORE YARD AREAS WITH 4" OF CLEAN TOPSOIL, INDOT TYPE 'U' WITHOUT CLOVER, COVER WITH EROSION CONTROL BLANKET. LEAVE TOP SOIL SLIGHTLY LOWER THAN SIDEWALK AND DRIVE APPROACH FOR DRAINAGE. THE CONTRACTOR IS RESPONSIBLE TO ACHIEVE 70% EVEN COVERAGE
3. APPLY WHITE PIGMENT SEALER. APPLY A DOUBLE COAT OF SEALER FROM SEPT. 1 THROUGH MARCH 31 TO PROTECT AGAINST WINTER SALT
4. DEFECTS OR QUALITY ISSUES MAY REQUIRE SECTIONS OF THE SIDEWALK TO BE REMOVED AND RE-POURED. THE CITY REPRESENTATIVE SHALL DETERMINE IF SECTIONS OF THE SIDEWALK WILL NEED RE-POURED
5. A PRE-POUR AND POST-POUR INSPECTION IS REQUIRED FOR ACCEPTANCE OF THE SIDEWALK. CALL THE CITY ENGINEERING DEPARTMENT TO SCHEDULE AN INSPECTION AT (574) 534-2201 OR ONLINE, 48 HOUR NOTICE REQUIRED FOR SCHEDULING
6. IF UNABLE TO ADJUST WATER SERVICE OR VALVE BOX CONTACT THE CITY WATER & SEWER DEPARTMENT AT (574) 534-5306

SIDEWALK CROSS SLOPE TARGET OF 1.5%  
(2.0% MAX PER CURRENT ADA STANDARDS)

4.0' MIN. CLEAR PATH FROM OBSTACLES  
(PER CURRENT ADA STANDARDS)

6.0' WIDTH (TYP.)

BROOM FINISH SURFACE

CONCRETE CURB

MATCH JOINT LOCATION BETWEEN CURB AND SIDEWALK WHEN POSSIBLE

1/2" FIBER BOARD OR FOAM EXPANSION MATERIAL, FULL DEPTH. INSTALL BETWEEN CURB AND SIDEWALK. TOP OF EXPANSION MATERIAL SHALL BE EVEN WITH TOP OF CURB AND SIDEWALK

STAMP CURB AT LOCATION OF SEWER LATERAL AND WATER SERVICE, 2" MIN. TEXT SIZE

## **SIDEWALK ADJACENT TO CONCRETE CURB**

NOT TO SCALE