



1. **TRACER WIRE ACCESS POINTS SHALL BE A MAXIMUM OF 500' APART**
2. **ACCESS POINTS SHALL BE LOCATED AT VALVES, BOXES, ROAD CROSSINGS, MAJOR PIPE TURNS OR DIRECTIONAL CHANGES**



NOT TO SCALE