

CHECK FOR COMPLIANCE BY MEASURING
FROM THE VALVE NUT SIDE OR CORNER
CLOSES TO THE VALVE BOX BODY



PLUMB LINE FROM VALVE NUT
(ESTABLISHED WITH PLUMB BOB)

NOTES:

1. CITY REPRESENTATIVE WILL INSPECT WATER VALVE BOXES FOR ACCEPTANCE PRIOR TO PATCHING OR PAVING
2. CONTRACTOR MAY USE OTHER METHODS TO CHECK FOR PLUMB DURING INSTALLATION. THE METHOD SHOWN IS FOR AN EXAMPLE
3. CLEAN ASPHALT FROM LID AND CASTING. INSURE THE LIFTING NOTCHES ARE CLEAN AND THE LID SITS FLUSH WITH THE CASTING
4. REMOVE ALL DEBRIS THAT HAS FALLEN INTO THE VALVE BOX BEFORE FINAL INSPECTION


VALVE NUT

CENTERING DISK



ACCEPTABLE VALVE BOX ALIGNMENT

PLAN VIEW



UNACCEPTABLE VALVE BOX ALIGNMENT

PLAN VIEW

WATER VALVE BOX ACCEPTANCE STANDARD

NOT TO SCALE

The City Of Goshen
Department of Public Works & Safety
Office of Engineering

204 East Jefferson, Suite 1 Street, Goshen, Indiana 46528
Phone: 574-534-2201 Fax: 574-533-8626
Web: goshenindiana.org

Date Approved By The City Of Goshen Board Of Public Works & Safety and Approved Revisions

03/27/2025

CITY OF GOSHEN, INDIANA
STANDARD DETAIL

Drafted By: J. Hoffman
Approved By: D. Sailor, P.E.

Drawing Number:
WA-110