



NOTES:

1. OPEN CUT INSTALLATION - TRACER WIRE (BLUE) TO BE COPPERHEAD HIGH STRENGTH 1245 OR APPROVED EQUAL
2. DIRECTIONAL BORING - TRACER WIRE (BLUE) TO BE COPPERHEAD SOLOSHOT 1245 OR APPROVED EQUAL
3. WIRE SPLICES TO BE MADE WITH SNAKEBITE OR 3M DBR CONNECTORS
4. FUSED MECHANICAL FITTINGS REQUIRED
5. LIVE TAP FOR WATER MAINS, LESS THAN OR EQUAL TO 12" DIA., TO BE INSTALLED BY CITY. MATERIAL SUPPLIED BY CONTRACTOR. CONTRACTOR TO EXPOSE WATER MAIN AND PREPARE THE AREA FOR CITY TAP EQUIPMENT (SEE DETAIL WA-101)

4" COMMERCIAL HDPE WATER SERVICE

NOT TO SCALE