

STAMP CURB AT LOCATION OF SEWER LATERAL AND WATER SERVICE, 2" MIN. TEXT SIZE

SIDEWALK ADJACENT TO CONCRETE CURB

NOT TO SCALE

2.0' MIN. FROM SIDEWALK (FIRE HYDRANT)

SAW CUT CONTRACTION JOINT AT CASTINGS WITHIN SIDEWALK

-USE A PLUG CURB BOX LID WITH 1" PENTAGON PLUG
WHEN THE CURB BOX IS LOCATED WITHIN A HARD
SURFACE AREA. INSTALL ±1/8" LOWER THAN FINISHED
SURFACE TO PREVENT A TRIP HAZARD. IF HIGH OR LOW
AND WOULD CAUSE A TRIP HAZARD, THE PANEL WILL
NEED REPLACED AND CURB BOX ADJUSTED. IF UNABLE
TO ADJUST AN EXISTING CURB STOP, CONTACT THE CITY
SEWER AND WATER DEPARTMENT FOR ASSISTANCE
NO EXPANSION MATERIAL OR PVC PIPE AROUND LID

USE NEENAH R-1976 OR EQUAL CASTING OVER PVC CLEANOUT WITHIN A HARD SURFACE AREA. INSTALL ±1/8" LOWER THAN FINISHED SURFACE TO PREVENT A TRIP HAZARD. WORD 'SEWER' STAMPED ON LID. NO EXPANSION MATERIAL OR PVC PIPE AROUND CASTING

NOTES:

- 1. 4" CLASS 'A' CONCRETE, 4,000 PSI OVER 4"
 COMPACTED No 53 CRUSHED/RECYCLED CONCRETE.
 LIMESTONE OR PROCESSED GRAVEL MAY BE USED IF
 CRUSHED/RECYCLED CONCRETE IS UNAVAILABLE
 WITH APPROVAL BY ENGINEERING DEPT.
- 2. RESTORE YARD AREAS WITH 4" OF CLEAN TOPSOIL, INDOT TYPE 'U' WITHOUT CLOVER, COVER WITH EROSION CONTROL BLANKET. LEAVE TOP SOIL SIGHTLY LOWER THAN SIDEWALK AND DRIVE APPROACH FOR DRAINAGE. THE CONTRACTOR IS RESPONSIBLE TO ACHIEVE 70% EVEN COVERAGE
- 3. APPLY WHITE PIGMENT SEALER. APPLY A DOUBLE COAT OF SEALER FROM SEPT. 1 THROUGH MARCH 31 TO PROTECT AGAINST WINTER SALT
- 4. DEFECTS OR QUALITY ISSUES MAY REQUIRE SECTIONS OF THE SIDEWALK TO BE REMOVED AND RE-POURED. THE CITY REPRESENTATIVE SHALL DETERMINE IF SECTIONS OF THE SIDEWALK WILL NEED RE-POURED
- 5. A PRE-POUR AND POST-POUR INSPECTION IS REQUIRED FOR ACCEPTANCE OF THE SIDEWALK. CALL THE CITY ENGINEERING DEPARTMENT TO SCHEDULE AN INSPECTION AT (574) 534-2201 OR ONLINE, 48 HOUR NOTICE REQUIRED FOR SCHEDULING
- 6. IF UNABLE TO ADJUST WATER SERVICE OR VALVE BOX CONTACT THE CITY WATER & SEWER DEPARTMENT AT (574) 534-5306