


SPACER MATERIAL SPECIFICATIONS

1. SHELL - MINIMUM 14 GAUGE T-304 STAINLESS STEEL. ALL SURFACES ARE FULLY CHEMICALLY PASSIVATED. FLANGES ARE RIBBED FOR STRENGTH
2. RISERS - MAXIMUM 10 GAUGE T-304 STAINLESS STEEL, REINFORCED 6" AND OVER IN HEIGHT
3. FASTENERS - 5/16 - 18 T-304 STAINLESS STEEL
4. LINER - PVC, 0.90 THICK, 85-90 DUROMETER (ASTM D1706 - 61T)
MAX. CONSTANT OPERATING TEMPERATURE - 150 DEGREES (F)
ELECTRICAL PROPERTIES - (ASTM - D149 - 61) 1380 V/min.
RESISTANCE - SALT SPRAY (ASTM - B117) EXCELLENT
- ACIDS GOOD
5. RUNNERS - ULTRA HIGH MOLECULAR WEIGHT POLYETHYLENE
LOW COEFFICIENT OF FRICTION
HIGH RESISTANCE TO ABRASION AND SLIDING WEAR
TOUGHNESS UNDER IMPACT
LOW DEFLECTION UNDER COMPRESSION
DIELECTRIC INSULATION

CASCADE CASING SPACERS MODEL CCS AS MANUFACTURED BY
CASCADE WATERWORKS MFG. OR APPROVED EQUAL



SECTION A-A

NOTES:

1. SUBMIT SHOP DRAWINGS TO THE CITY ENGINEERING DEPARTMENT FOR APPROVAL
2. ALL CHANGES TO MATERIALS OR MODIFICATIONS TO PLANS MUST BE PRE-APPROVED BY THE CITY ENGINEERING DEPARTMENT
3. RECORD DRAWING SHALL INCLUDE ELEVATION AT EACH END OF THE PIPE AND CASING, LOCATION OF EACH OF THE CASING, CASING LENGTH, SIZE, TYPE, A PROFILE DRAWING OF THE CASING CONTAINING THE ABOVE INFORMATION. INCLUDE ANY SPECIAL CONDITIONS OR NOTES

SEWER CASING

NOT TO SCALE