


- 1. FIRE HYDRANT SHALL BE MIN. 1.0' FROM PROPERTY LINE, MIN. 3.0' FROM BACK OF CURB AND/OR MIN. 2.0' FROM SIDEWALK
- 2. FIRE HYDRANT ASSEMBLY TO INCLUDE TEE AT WATER MAIN, ALL CONNECTING PIPE AND FITTINGS, AUXILIARY GATE VALVE AND BOX AND FIRE HYDRANT
- 3. GUARD POSTS ARE TO PROTECT A FIRE HYDRANT IN AREAS WHERE VEHICULAR OR EQUIPMENT TRAFFIC MAY BE ENCOUNTERED. REQUIREMENT **DETERMINED BY CITY**
- 4. NO STRUCTURES, POLES, SIGN POSTS, TREES OR SHRUBS TO BE INSTALLED WITHIN 4.0' OF FIRE HYDRANT
- 5. PRIVATE HYDRANT COLOR = RED PUBLIC HYDRANT COLOR = YELLOW

NOTES:

- 6. ACCEPTED FIRE HYDRANTS: CLOW MEDALLION AND KENNEDY K81D
- 7. SEE DETAILS RD-206 AND RD-207 FOR FIRE HYDRANT LOCATION



## FIRE HYDRANT ASSEMBLY

VALVE AT WATER MAIN TEE